



Opteon™ XP44

Refrigerant (R-452A)

Product Information

Opteon™ XP44 (R-452A) is a non-ozone depleting, low Global Warming Potential (GWP) hydrofluoro-olefin based refrigerant developed to replace R-404A/R-507A in positive displacement, direct expansion low and medium temperature refrigeration applications where low discharge temperatures are required. Opteon™ XP44 is suitable in new equipment as well as for retrofit of existing systems, offering comparable energy efficiency with improved environmental properties but without increased compressor discharge temperatures.

Applications

- Low and medium temperature transport DX refrigeration
 - Refrigerated trucks
 - Refrigerated vans
 - Reefer containers
- Low and medium temperature commercial and industrial DX refrigeration
- New equipment/retrofit of existing systems
- Ideal for low temperature hermetic compressor systems

Benefits

- Non-ozone depleting and lower GWP (approx. 50 % reduction vs. R-404A/R-507A) ¹⁾
- No increase in compressor discharge temperature compared to R-404A
- Comparable energy efficiency vs. R-404A/R-507A
- Provides quick, easy and low cost retrofit from R-404A/R-507A

- Safe and non-flammable (ASHRAE ²⁾ A1)
- Approved and adopted by major equipment manufacturers
- Alternative to R-407 series low and medium temperature refrigerants
- Miscible with POE lubricants
- Can be topped off after leaks

Opteon™ XP44 properties

ASHRAE Number	R-452A
Composition Wt %	R-32/R-125/R-1234yf 11.0/59.0/30.0
Molecular Weight	103.5 g/mol
Boiling Point @ 1 atm (101.3 kPa)	-47.0 °C
Critical Pressure	4002 kPa
Critical Temperature	74.9 °C
Liquid Density @ 21.1 °C	1148.8 kg/m ³
Ozone Depletion Potential (CFC-11 = 1.0)	0
AR4 Global Warming Potential (CO ₂ = 1.0)	2141
ASHRAE Safety Classification	A1
Temperature Glide	~3 K

1) According to Assessment Report 4 (AR4) which is the basis for the F-Gas regulation (EU) No. 517/2014.

2) American Society of Heating, Refrigerating and Air-Conditioning Engineers

What to expect after retrofitting

The data below was obtained from theoretical cycle calculations for medium temperature (-8 °C mean evaporating temperature) and low temperature (-35 °C mean evaporating temperature) refrigeration scenarios. For both the medium and low temperature scenarios the following parameters were used; evaporator superheat = 8 K, Suction line Superheat = 12 K, Liquid subcooling = 2 K and compressor isentropic efficiency = 70%. ³⁾

	Medium Temperature		Low Temperature	
	30 °C	45 °C	30 °C	45 °C
Mean Condensing Temperature	30 °C	45 °C	30 °C	45 °C
Cooling Capacity	+1%	+2%	-1%	-1%
C.O.P.	+1%	+2%	+1%	+2%
Relative Mass Flow	+2%	+1%	-1%	-1%
Suction Pressure	-13 kPa	-16 kPa	-9 kPa	-10 kPa
Discharge Pressure	+5 kPa	+15 kPa	+5 kPa	+15 kPa
Discharge Temperature	+2.2 K	+2.3 K	+2.5 K	+2.7 K

+ is an increase, - is a decrease relative to R-404A

³⁾ Actual performance for a specific system depends on a number of factors, including equipment conditions and operating environment.

For more information on the Opteon™ family of refrigerants or other Chemours Refrigerants products visit [opteon.com](https://www.opteon.com)

The information set forth herein is furnished free of charge and based on technical data that Chemours believes to be reliable. It is intended for use by persons having technical skill, at their own risk. Because conditions of use are outside our control, Chemours makes no warranties, expressed or implied, and assumes no liability in connection with any use of this information. Nothing herein is to be taken as a license to operate under, or a recommendation to infringe, any patents or patent applications.

© 2016 The Chemours Company FC, LLC. Opteon™ and the Opteon Logo are trademarks or registered trademarks of The Chemours Company. Chemours™ and the Chemours Logo are trademarks of The Chemours Company.